



### END DETAIL

### SECTION A-A

CARRIER PIPE DIA	TYPICAL CASING DIA REQUIRED
6"	16"
8"	24"
12"	24"
16"	36"
18"	36"
20"	36"
24"	48"

### NOTES:

1. REQUIRED CASING MATERIAL AND WALL THICKNESS DEPENDENT UPON INSTALLATION METHOD, DEPTH OF BURY, SOIL CONDITIONS, AND OTHER FACTORS. CASING DIAMETER MAY NEED TO BE INCREASED TO ACCOMMODATE GREATER WALL THICKNESS OF CARRIER PIPE OR CASING.
2. PROVIDE 2" MINIMUM CLEARANCE BETWEEN CASING AND CARRIER PIPE BELLS AND APPURTENANCES.
3. VERIFY CASING SIZES PRIOR TO ORDERING AND SIZING CASING INSULATORS.
4. ALL CARRIER PIPE TO BE RESTRAINED.



ENGINEERING DEPARTMENT  
13125 S.W. HALL BLVD.  
TIGARD, OREGON 97223  
VOICE: (503) 639-4171  
FAX: (503) 684-7297

DATE REVISION

## PIPE CASING

NO SCALE

DWG. NO.

**580**